

Mrs. Nadine Joosten Arte nv Industriezone "De Waerde" Senator A. Jeurissenlaan 1210 B-3520 Zonhoven

Your message - reference	our reference	Gent
-	PW/2193	2021-06-21

Certification report 19/2193

1. Description of the wall covering:

ï

Product family	Type 4a: Three dimensional Wallcovering (foam 5mm)
Total mass	Ca. 735-955 g/m²

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

addressee	our reference	Gent	page
Arte nv	PW/2193	2021-06-21	2

C – s1, d0

field of application: glued on end-use substrates having a density of 1350 kg/m3 or higher and classified

A2-s1,d0 or A1.

ī

Related commercial names to this product group	VELVETEEN ECLIPSE BLACK & WHITE: Caisson, Charm INTRIGUE: Caisson SPECTRA: Parquet, Cannage, Caisson MOOOI: Dwarf Rhino, Dodo Pavone, Flying Coral MOOOI TOKYO BLUE: Shoji Blossom MOOOI Spring 2021: Mimic Moth ICONS: Curve YALA
The obtained classification is based on the next test reports	AITEX: 2019AN2689 AITEX: 2020AN2201
Validity of the certificate	2024-10-14

Petra Wittevrongel

Product Certifier