



**Arte nv**  
**Industriezone "De Waerde"**  
**Senator A. Jeurissenlaan 1210**  
**B-3520 Zonhoven**

**Your message - reference**

-

**our reference**

PW/745

**Gent**

2021-02-04

Certification report 19/745

---

## 1. Description of the wall covering:

<b>Product family</b>	Type 02: Wallcovering with natural materials and decorative elements
<b>Total mass</b>	226 g/m <sup>2</sup> - 650 g/m <sup>2</sup>

## 2. Test results:

Classification according to EN13501-1:2007+A1 (2009)

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**

**GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)**

**VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB**

**addressee**

Arte nv

**our reference**

PW/745

**Gent**

2021-02-04

**page**

2

**3. Conclusion:**

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

<b>B - s1, d0</b>
-------------------

*field of application: glued (starch glue applied at the rate of 200 gr/m<sup>2</sup>) on end-use substrates having a density of 1350 kg/m<sup>3</sup> or higher and classified A2-s1,d0 or A1.*

**Related commercial names to this product group**

Artisan Bark Cloth Boracay Caraboa Cantala Expedition: Java Heliodor Icons: Rattan, Waffle weave Insero	Ligna: Scope Manovo Moooi: Armoured Bear, Bearded Leopard Moooi Tokyo Blue : Lucky O's Oculaire Revera: Align Takara: Harmony, Spirit, Air, Feather Timber Wildwalk: Ferox
--	---

**The obtained classification is based on the next test reports**

CREPIM: 1039/82/010 B  
 AITEX: 2019AN0390

**Validity of the certificate**

20/02/2022

Petra Wittevrongel

Product Certifier

