



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

PW/745

Gent

2019-04-03

Certification report 19/745

1. Description of the wall covering:

Product family	Type 02: Wallcovering with natural materials and decorative elements
Total mass	226 g/m ² - 650 g/m ²

2. Test results:

Classification according to EN13501-1:2007+A1 (2009)

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples. Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



CENTEXBEL • textile competence centre • www.centexbel.be
GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be
VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee

Arte nv

our reference

PW/745

Gent

2019-04-03

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

B - s1, d0

field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1.

Related commercial names to this product group	<table border="1"> <tr> <td>Artisan Bark Cloth Boracay Caraboa Cantala Heliodor Insero</td> <td>Ligna: Scope Mooui Oculaire Revera: Align Takara: Harmony, Spirit, Air, Feather Timber</td> </tr> </table>	Artisan Bark Cloth Boracay Caraboa Cantala Heliodor Insero	Ligna: Scope Mooui Oculaire Revera: Align Takara: Harmony, Spirit, Air, Feather Timber
Artisan Bark Cloth Boracay Caraboa Cantala Heliodor Insero	Ligna: Scope Mooui Oculaire Revera: Align Takara: Harmony, Spirit, Air, Feather Timber		
The obtained classification is based on the next test reports	<p>CREPIM: 1039/82/010 B</p> <p>AITEX: 2019AN0390</p>		
Validity of the certificate	20/02/2022		

Petra Wittevrongel

Product Certifier

