

Arte nv Industriezone "De Waerde" Senator A. Jeurissenlaan 1210 B-3520 Zonhoven

Your message - reference	our reference	Gent
· -	PW/722	2019-04-03

Certification report 19/722

1. Description of the wall covering:

Product family	Type 06: Decorative wall covering with textile
Total mass	195-595 g/m²

2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



addressee	our reference	Gent	page
Arte nv	PW/722	2019-04-03	2

B - s1, d0

field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m3 or higher and classified A2-s1,d0 or A1.

Related commercial names to this product group	Amazone 2
	Avalon Glade
	Insolence: Grow, Swing
	MOOOI: Menagerie of extinct animals
	TAKARA: Noble
	VANGUARD: Expressionist
The obtained classification is based	CSI: 0889/DC/REA/18-3 dated 11-09-18
on the next test reports	CSI: 1075/DC/REA/18-3 dated 15-10-18
	Aitex: 2019AN0452 dated 06-03-19
Validity of the certificate	2023-09-10

Petra Wittevrongel

Product Certifier