



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

PW/211

Gent

2021-06-21

Certification report 19/211

1. Description of the wall covering:

| | |
|-----------------------|---|
| Product family | Type 4: Decorative wall covering consisting of: Decorative wallcovering: Non-woven + 5mm mousse |
| Total mass | Ca. 520 g/m ² |

2. Test results:

| | |
|-------------------------------|----------|
| EN ISO 11925-2 (exposure=30s) | EN 13823 |
|-------------------------------|----------|

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples. Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

addressee

Arte nv

our reference

PW/211

Gent

2021-06-21

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

B – s1, d0

field of application: glued on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1

Related commercial names to this product group

Eclips Black & White: Feuillage
ENIGMA: Select
Intrigue: Feuillage
Le Corbusier: Sqaures

The obtained classification is based on the next test reports

AITEX: 2020AN2203

Validity of the certificate

2026-01-18

Petra Wittevrongel

Product Certifier

