



**Arte nv**  
**Industriezone "De Waerde"**  
**Senator A. Jeurissenlaan 1210**  
**B-3520 Zonhoven**

**Your message - reference**

-

**our reference**

PW/1155

**Gent**

2020-05-18

Certification report 20/1155

---

### 1. Description of the wall covering:

<b>Product family</b>	Type 06d: Decorative wall covering with textile
<b>Total mass</b>	755-815 g/m <sup>2</sup>

### 2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**

**GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)**

**VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB**

**addressee**

Arte nv

**our reference**

PW/1155

**Gent**

2020-05-18

**page**

2

## C - s1, d0

*field of application: glued (100% dispersion glue applied at the rate of 250 gr/m<sup>2</sup>) on end-use substrates having a density of 1350 kg/m<sup>3</sup> or higher and classified A2-s1, d0 or A1.*

**Related commercial names to this product group**

MOOOI Tokyo Blue 'the indigo macaque'

**The obtained classification is based on the next test reports**

Aitex: 2020AN0625 dated 17-04-20

**Validity of the certificate**

2025-04-16

Petra Wittevrongel

Product Certifier

