

Arte nv Industriezone "De Waerde" Senator A. Jeurissenlaan 1210 B-3520 Zonhoven

| Your message - reference | our reference | Gent |
|-----------------------------|---------------|------------|
| - | PW/720 | 2020-02-17 |
| Certification report 19/720 | | |

1. Description of the wall covering:

| Product family | Type 03: Vinyl wallcovering with water based ink |
|----------------|--|
| Total mass | Ca 330 - 605 g/m² |

2. Tests executed:

| EN ISO 11925-2 (exposure=30s) | EN 13823 |
|-------------------------------|----------|
| | |

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



| addressee | our reference | Gent | page |
|-----------|---------------|------------|------|
| Arte nv | PW/720 | 2020-02-17 | 2 |

 $B-s2,\ d0$ field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m3 or higher and classified A2-s1,d0 or A1.

| Related commercial names to this | Atelier |
|--------------------------------------|--------------------------------------|
| product group | Artic Fever |
| | Avalon |
| | Curiosa |
| | Expedition: Tasar, Sumatra, Eri |
| | Figura |
| | Focus |
| | Galena |
| | Lino |
| | Mahlia |
| | Mirage |
| | Monsoon |
| | New Heritage |
| | Signature |
| | Selva |
| The obtained classification is based | Aitex: 2018AN2975 dated 22-10-2018 |
| | 7 Mex. 2010/11/23/3 dated 22 10 2010 |
| on the next test reports | Aitex: 2019AN0293 dated 07-03-2019 |
| | |
| Validity of the certificate | 2023-10-21 |

Petra Wittevrongel Product Certifier