



Mrs. Evi Smets
Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

PW/667

Gent

2018-04-05

Certification report 18/667

1. Description of the wall covering:

Product family	Type 06c: Decorative wall covering consisting of: Nonwoven substrate + Fabric
Total mass	850 g/m ²

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee

Arte nv

our reference

PW/667

Gent

2018-04-05

page

2

D - s1, d0

Glued (starch glue applied at the rate of 250 g/m²) on a calcium silicate substrate having a density of (870±50) kg/m³, 11±2 mm thick with a fire performance of class A2-s1, d0 (EN 13238)

Related commercial names to this product group

Takare Crane

The obtained classification is based on the next test reports

Aitex: 2018AN0494

Validity of the certificate

01-03-2023

Petra Wittevrongel

Product Certifier

