



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

PW/722

Gent

2021-02-04

Certification report 19/722

1. Description of the wall covering:

Product family	Type 06: Decorative wall covering with textile
Total mass	195-595 g/m ²

2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.
Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

addressee

Arte nv

our reference

PW/722

Gent

2021-02-04

page

2

B - s1, d0

field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1.

Related commercial names to this product group

All'ombra dei cipressi
Amazone 2
Avalon: Glade
Bird of paradise
Blooming pineapple
Expedition: Silk Road Garden
Hills of Sapa
Insolence: Grow, Swing
Kami: Dupion, Koi, Kimono
Le jardin Mystique
Les grenouilles de Chavroches
Les mystères de Madagascar
Les songes Toscans
Lush: Tinneroy, Corduroy, Tropicalia, Wildflower
MOOOI: Menagerie of extinct animals
MOOOI Tokyo Blue: Rendez-vous Tokyo blue, Tie-Tami
Palafitas Amazonia
Pavartina
Takara: Noble
Vanguard: Expressionist
Wildwalk: Noble
Wonderwoods

The obtained classification is based on the next test reports

CSI: 0889/DC/REA/18-3 dated 11-09-18
CSI: 1075/DC/REA/18-3 dated 15-10-18
Aitex: 2019AN0452 dated 06-03-19

Validity of the certificate

2023-09-10

Petra Wittevrongel

Product Certifier

